



IEC TS 62749

Edition 3.0 2026-03

INTERNATIONAL STANDARD

REDLINE VERSION

Assessment of power quality - Characteristics of electricity supplied by public networks

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Recommended values for power quality indices.....	17
4.1 General.....	17
4.2 Frequency deviation.....	19
4.3 Supply voltage deviation	19
4.3.1 General	19
4.3.2 Low voltage systems	19
4.3.3 Medium voltage systems.....	19
4.3.4 High voltage systems.....	20
4.4 Voltage unbalance	20
4.5 Flicker.....	21
4.6 Harmonic and interharmonic voltage	21
4.6.1 General	21
4.6.2 Low voltage systems	21
4.6.3 Medium voltage systems.....	22
4.6.4 High voltage systems.....	24
4.7 Voltage dip	25
4.8 Voltage swell	25
4.9 Voltage interruption.....	25
4.10 Mains communicating voltage	26
4.11 Rapid voltage change	27
4.12 Transient overvoltage	27
4.12.1 Low voltage systems	27
4.12.2 Medium and high voltage systems	28
5 Objectives and methods for power quality assessment	28
5.1 General.....	28
5.2 Site power quality assessment.....	29
5.2.1 General	29
5.2.2 Continuous phenomena	29
5.2.3 For discontinuous phenomena (single event)	31
5.3 System aspect power quality assessment	32
5.3.1 General	32
5.3.2 For continuous phenomena.....	32
5.3.3 For discontinuous phenomena (events)	32
Annex A (informative) Examples of profiles for power quality specification.....	35
A.1 General.....	35
A.2 LV and MV public distribution electricity networks in European countries	35
A.3 LV, MV and HV power supply system in China	37
A.4 Example of a transmission system in Canada	38
A.5 Examples of profiles in Australia	39
A.6 LV, MV and HV power supply system in Russia	40
Annex B (informative) Additional information on power quality assessments	42

B.1	Weekly percentile values assessed on a daily sliding basis.....	42
B.2	Example on system aspect continuous disturbance evaluation.....	43
B.3	Aggregation method used for events.....	43
B.3.1	General.....	43
B.3.2	Time aggregation.....	44
Annex C (informative) Main impact of poor power quality.....		
Annex C (informative)	Power quality issues related to distributed generation and micro-grids.....	49
C.1	General.....	49
C.2	Voltage deviation.....	49
C.3	Harmonics.....	49
C.4	DG magnetic bias (DC current injection).....	49
C.5	Voltage fluctuation and flicker.....	50
C.6	High frequency conducted disturbances.....	50
Annex D (informative)	Methods to maintain and improve power quality.....	51
D.1	General.....	51
D.2	Voltage deviation.....	51
D.3	Harmonics.....	52
D.4	Flicker.....	52
D.5	Voltage unbalance.....	52
D.6	Voltage dip, swell and short time interruption.....	53
Annex E (informative)	Relation between power quality and EMC.....	54
E.1	General.....	54
E.2	Differences between power quality and compatibility levels.....	54
E.3	Example of power quality level versus compatibility level.....	55
Annex F (informative)	Other phenomena.....	58
F.1	General.....	58
F.2	Level behaviour over time.....	58
F.3	Duration.....	58
F.4	Periodicity.....	58
F.5	Bandwidth.....	59
Annex G (informative)	Role of stakeholders for power quality management – Coordination of the parties involved.....	60
G.1	General.....	60
G.2	Network operator – Network user.....	60
G.3	Network user – Equipment supplier.....	60
G.4	Network operator – Equipment supplier.....	61
Bibliography	62
Figure 1	– Mains communicating voltages recommended values in percent of U_N used in public LV networks (or U_C in public MV networks).....	27
Figure 2	– Example for illustrating voltage <i>THD</i> assessment result trends.....	31
Figure 3	– Example showing information of single event assessment.....	32
Figure B.1	– Comparison of two methods of assessing weekly 95 th percentile values.....	42
Figure B.2	– Example for illustrating the differences resulted by time aggregation method.....	44

Figure B.3 – Example of time sequence of voltage dips that can be aggregated in two different ways	45
Figure E.1 – Application points in a LV system (example)	54
Figure E.2 – Relation between disturbance levels (schematic significance only)	55
Figure E.3 – Cumulative distribution of all <i>THD</i> values recorded at 30 points of supply of the LV system, during one week	56
Figure E.4 – Weekly 95 th percentile <i>THD</i> values evaluated at each monitored LV point of supply	57
Table 1 – Classification of electromagnetic phenomena addressed by power quality indices	7
Table 2 – Flicker severity P_{ft} recommended values	21
Table 3 – Recommended values of individual harmonic voltages at the low voltage points of supply for orders up to 50 40 given in percent of the fundamental voltage U_1	22
Table 4 – Recommended values of individual harmonic voltages at the medium voltage points of supply for orders up to 50 40 given in percent of the fundamental voltage U_1	23
Table 5 – Indicative values of individual harmonic voltages at the high voltage points of supply given in percent of the fundamental voltage U_1	24
Table 6 – Site power quality assessment methods	30
Table 7 – Example of single event assessment	31
Table 8 – List of individual events measured at a single monitoring site	33
Table 9 – SARFI-X indices coming out of Table 8	33
Table 10 – Magnitude-duration table format	34
Table A.1 – Examples of profiles in most European countries	35
Table A.2 – Examples of profiles in Spain	36
Table A.3 – Examples of profiles in China	37
Table A.4 – Examples of profiles in Canada	38
Table A.5 – Examples of profiles in Australia	39
Table A.6 – Examples of profiles in Russia	40
Table B.1 – Listing of system power quality evaluation	43

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Assessment of power quality -
Characteristics of electricity supplied by public networks**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with can participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC TS 62749:2020. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC TS 62749 has been prepared by IEC technical committee 8: System aspects of electrical energy supply. It is a Technical Specification.

This third edition cancels and replaces the second edition published in 2020. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) clarification that harmonic orders recommended in this document are up to 40th; 4.6 is modified accordingly;
- b) iteration that this document does not apply for systems operated above 230 kV;
- c) deletion of Annex C;
- d) improvement of 4.10;
- e) update of profiles and addition of new profiles;
- f) modifications to align with EN 50160:2022 and EN 50160:2022/AMD1:2025.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
8/1779/DTS	8/1800/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

The description of electricity is of fundamental importance within electricity supply systems. In the past, its characteristics depended less on its generation than on the way in which it was transported by networks and being used by the equipment of the multiple users. Faults or other events such as short-circuit and lightning strikes occurring within users' installations or public networks also disturb or degrade it.

Nowadays, smart grid construction and massive deployment of renewable energy sources increase the complexity of power quality management. For more information about power quality issues related to distributed generation and micro-grids, refer to Annex C.

NOTE For more information about role of stakeholders for power quality management, see Annex G.

There is a need for a common set of power quality (PQ) indices and measurement methods in order to allow different system operators to measure and report power quality in a consistent manner.

Regarding the limits or levels of power quality, the situation differs. Historically, the electrical systems in different countries/ or regions have been designed in different ways to cater for national/ or regional variations like different geographic, climatic or commercial conditions, etc. It is thus essential that any set of internationally agreed power quality limits or levels also recognize these differences, which depends namely on the system configuration, the transfer characteristics between the different voltage levels (attenuation or amplification), the actual disturbance levels on the system, etc.

Also, the quality of power is not absolute. Optimizing power quality should be carried out in a cost-effective manner to balance network user power quality requirements and willingness to pay for it with power quality supply costs.

Therefore, some of the objectives recommended hereafter allow for a range of values, or options, while still ensuring the coordination of disturbance levels between different parts of the system or voltage levels.

Then, the requirements to be applied can be expressed by the association of the IEC power quality framework from the normative part of this document and profiles. Examples of profiles are given in Annex A.

1 Scope

This document, which is a Technical Specification, specifies the expected characteristics of electricity at the point of supply of public low, medium and high voltage, 50 Hz or 60 Hz, networks, as well as power quality assessment methods.

This document does not apply for systems operated above 230 kV.

~~NOTE 1~~—The boundaries between the various voltage levels can be different for different countries/ or regions. In the context of this document, the following terms for system voltage are used:

- low voltage (LV) refers to $U_N \leq 1$ kV;
- medium voltage (MV) refers to 1 kV $< U_N \leq 35$ kV;
- high voltage (HV) refers to 35 kV $< U_N \leq 230$ kV.

~~NOTE 2~~—Because of existing network structures, in some countries/ or regions, the boundary between medium and high voltage can be different. This document applies to the phenomena listed in Table 1.

Table 1 – Classification of electromagnetic phenomena addressed by power quality indices

Continuous phenomena	Discontinuous phenomena – Events	Other phenomena
Frequency deviation	Supply interruption	Mains communicating voltages
Supply voltage deviation	Voltage dip	
Voltage unbalance	Voltage swell	
Harmonic voltage	Transient overvoltage	
Interharmonic voltage	Rapid voltage change	
Flicker (voltage fluctuation)		

NOTE 1 Specification of related measurement methods can be found in IEC 61000-4-30.

NOTE 2 Specification of the performance of related measuring instruments can be found in the IEC 62586 series.

~~NOTE 3~~ For information on power quality phenomena at low voltage direct current (LVDC) network, refer to IEC TR 63282.

While power quality is related to EMC in a number of ways, especially because compliance with power quality requirements depends on the control of cumulative effect of electromagnetic emission from all/ or multiple equipment and/or installations, this document is not an EMC publication (see also Annex E).

2 Normative references

~~The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.~~

~~IEC 60038, IEC standard voltages~~

Bibliography

- ~~[1] IEC 60050-121:1998, International Electrotechnical Vocabulary – Part 121: Electromagnetism~~
- [1] IEEE Std 519-1992, *IEEE Recommended practice and requirements for harmonic control in electric power systems*³
- [2] CENELEC TR 50422, *Guide for the application of the European Standard EN 50160*
- [3] CIGRE Technical Brochure 261, *Power Quality Indices and Objectives*, Working Group C4.07, October 2004
- [4] IEEE Std 1564-2014, *IEEE Guide for Voltage Sag Indices*
- [5] AS 61000.3.100, *Australian Standard - Electromagnetic compatibility (EMC) Limits - Steady state voltage limits in public electricity systems*
- [6] IEC 60050-121, *International Electrotechnical Vocabulary (IEV) -- Part 121: Electromagnetism, available at www.electropedia.org*
- [7] IEC 60050-161, *International Electrotechnical Vocabulary (IEV) - Part 161: Electromagnetic compatibility, available at www.electropedia.org*
- [8] IEC 60050-601:~~1985~~, *International Electrotechnical Vocabulary (IEV) - Part 601: Generation, transmission and distribution of electricity - General, available at www.electropedia.org*
- [9] IEC 60050-614:~~2016~~, *International Electrotechnical Vocabulary (IEV) - Part 614: Generation, transmission and distribution of electricity - Operation, available at www.electropedia.org*
- [10] IEC 60050-617:~~2009~~, *International Electrotechnical Vocabulary (IEV) - Part 617: Organization/Market of electricity, available at www.electropedia.org*
- [11] IEC TR 60725, *Consideration of reference impedances and public supply network impedances for use in determining the disturbance characteristics of electrical equipment having a rated current ≤ 75 A per phase*
- [12] IEC TR 61000-2-1, *Electromagnetic compatibility (EMC) - Part 2: Environment – Section 1: Description of the environment - Electromagnetic environment for low frequency conducted disturbances and signalling in public power supply systems*
- [13] IEC 61000-2-4, *Electromagnetic compatibility (EMC) - Environment - Compatibility levels in power distribution systems in industrial-~~plants~~ locations for low-frequency conducted disturbances*
- [14] IEC TR 61000-2-5:2017, *Electromagnetic compatibility (EMC) - Part 2-5: Environment - Description and classification of electromagnetic environments*
- [15] IEC TR 61000-2-14, *Electromagnetic compatibility (EMC) - Part 2-14: Environment - Overvoltages on public electricity distribution networks*

³ This publication has been withdrawn.

- [16] IEC TR 61000-2-15, *Electromagnetic compatibility - Part 2-15: Description of the characteristics of networks with high penetration of power electronic converters*
- [17] IEC 61000-3-2, *Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*
- [18] IEC 61000-3-3, *Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection*
- [19] IEC TR 61000-3-6:2008, *Electromagnetic compatibility (EMC) - Part 3-6: Limits - Assessment of emission limits for the connection of distorting installations to MV, HV and EHV power systems*
- [20] IEC TR 61000-3-7, *Electromagnetic compatibility (EMC) - Part 3-7: Limits - Assessment of emission limits for the connection of fluctuating load installations to MV, HV and EHV power systems*
- [21] IEC 61000-3-11, *Electromagnetic compatibility (EMC) - Part 3-11: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems - Equipment with rated current ≤ 75 A and subject to conditional connection*
- [22] IEC 61000-3-12, *Electromagnetic compatibility (EMC) - Part 3-12: Limits - Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current >16 A and ≤ 75 A per phase*
- [23] IEC TR 61000-3-13, *Electromagnetic compatibility (EMC) - Part 3-13: Limits - Assessment of emission limits for the connection of unbalanced installations to MV, HV and EHV power systems*
- [24] IEC TR 61000-3-14, *Electromagnetic compatibility (EMC) - Part 3-14: Assessment of emission limits for harmonics, interharmonics, voltage fluctuations and unbalance for the connection of disturbing installations to LV power systems*
- [25] IEC 61000-4-7:2002, *Electromagnetic compatibility (EMC) - Part 4-7: Testing and measurement techniques - General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto*
IEC 61000-4-7:2002/AMD1:2008
- [26] IEC 61000-4-15, *Electromagnetic compatibility (EMC) - Part 4-15: Testing and measurement techniques - Flickermeter - Functional and design specifications*
- [27] IEC 61000-4-16:2015, *Electromagnetic compatibility (EMC) - Part 4-16: Testing and measurement techniques - Test for immunity to conducted, common mode disturbances in the frequency range 0 Hz to 150 kHz*
- [28] IEC 61000-4-19:2014, *Electromagnetic compatibility (EMC) - Part 4-19: Testing and measurement techniques - Test for immunity to conducted, differential mode disturbances and signalling in the frequency range 2 Hz to 150 kHz at a.c. power ports*
- [29] IEC 62586 (all parts), *Power quality measurement in power supply systems*
- [30] IEC TR 63222-100, *Power quality management - Part 100: Impact of power quality issues on electrical equipment and power system*

- [31] IEC TR 63282, *LVDC systems - Assessment of standard voltages and power quality requirements*
- [32] EN 50160:2022, *Voltage characteristics of electricity supplied by public electricity networks*
EN 50160:2022/AMD1:2025
- ~~[24] CENELEC TR 50422, *Guide for the application of the European Standard EN 50160*~~
- [33] CENELEC TR 50555, *Interruption indexes*
- ~~[26] AS 61000.3.100, *Australian Standard - Electromagnetic compatibility (EMC) Limits - Steady state voltage limits in public electricity systems*~~
- ~~[27] IEEE 519, *IEEE Recommended practice and requirements for harmonic control in electric power systems*~~
- ~~[28] IEEE 1564-2014, *IEEE Guide for Voltage Sag Indices*~~
- ~~[30] NRS 048-2:2003, *Electricity supply - Quality of supply - Part 2: Voltage characteristics, compatibility levels, limits and assessment methods*~~
- ~~[31] CIGRE Technical Brochure 261, *Power Quality Indices and Objectives, Working Group C4.07, October 2004*~~
- [34] CEER Benchmarking Reports on the Quality of Electricity Supply
- NRS 048-2:2003, *Electricity supply - Quality of supply - Part 2: Voltage characteristics, compatibility levels, limits and assessment methods*
- [35] GB/T 18481, *Power quality - Temporary and transient overvoltages*
- [36] IEC 60038, *IEC standard voltages*
- [37] IEC 60364-4-44, *Low-voltage electrical installations - Part 4-44: Protection for safety - Protection against voltage disturbances and electromagnetic disturbances*
- [38] IEC 60364-5-53, *Low-voltage electrical installations - Part 5-53: Selection and erection of electrical equipment - Devices for protection for safety, isolation, switching, control and monitoring*
- [39] IEC 61000-2-2:2002, *Electromagnetic compatibility (EMC) - Part 2-2: Environment - Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems*
IEC 61000-2-2:2002/AMD1:2017
IEC 61000-2-2:2002/AMD2:2018
- [40] IEC 61000-2-12, *Electromagnetic compatibility (EMC) - Part 2-12: Environment - Compatibility levels for low-frequency conducted disturbances and signalling in public medium-voltage power supply systems*
- [41] IEC 61000-4-30:2015, *Electromagnetic compatibility (EMC) - Part 4-30: Testing and measurement techniques - Power quality measurement methods*

- [42] ITU-T G.9901:2017, *Narrowband orthogonal frequency division multiplexing power line communication transceivers - Power spectral density specification*
ITU-T G.9901:2017/AMD1:2023
-