



IEC 60730-2-5

Edition 5.0 2026-04

INTERNATIONAL STANDARD

**Automatic electrical controls -
Part 2-5: Particular requirements for automatic electrical burner control systems**

CONTENTS

FOREWORD	3
1 Scope	6
2 Normative references	7
3 Terms and definitions	8
4 General	15
5 Required technical information	16
6 Protection against electric shock	18
7 Provision for protective earthing	19
8 Terminals and terminations.....	19
9 Constructional requirements	20
10 Threaded parts and connections.....	28
11 Creepage distances, clearances and distances through solid insulation.....	28
12 Components	29
13 Fault assessment on electronic circuits	29
14 Moisture and dust resistance	30
15 Electric strength and insulation resistance	30
16 Heating.....	31
17 Manufacturing deviation and drift.....	31
18 Environmental stress	31
19 Endurance	32
20 Mechanical strength	35
21 Resistance to heat, fire and tracking.....	36
22 Resistance to corrosion	36
23 Electromagnetic compatibility (EMC) requirements – Emission	36
24 Normal operation	36
25 Electromagnetic compatibility (EMC) requirements – Immunity	36
26 Abnormal operation tests.....	36
Annex H (normative) Requirements related to functional safety	37
Annex J (normative) Requirements for thermistor elements and controls using thermistors.....	49
Annex Q (informative) Regional differences relevant for the member countries of Cenelec	50
Annex R (informative) National differences relevant in the United States of America.....	51
Annex S (informative) National differences relevant in Japan	52
Annex T (informative) National differences relevant in Canada	53
Annex AA (informative) Functional characteristics of burner control systems to be specified by the relevant appliance standards, as applicable	54
Bibliography.....	55
Figure 101 – Pulse spark generation.....	19
Figure 102 – Typical installation of the independent combustion air supply for room independent operation	28

Figure H.101 – Voltage variation test	44
Table 1 – Required technical information and methods of providing these information	16
Table H.1 – Additional items to Table 1.....	37
Table H.101 – Timing of short-term supply voltage variations	43
Table H.102 – Test levels for electrostatic discharge	46
Table AA.1 – Functional characteristics of burner control systems to be specified by the relevant appliance standards, as applicable	54

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Automatic electrical controls -
Part 2-5: Particular requirements for automatic
electrical burner control systems**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60730-2-5 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This fifth edition cancels and replaces the fourth edition published in 2013, Amendment 1:2017 and Amendment 2:2021. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

Adoption of IEC 60730-1:2022 with all of its significant changes to IEC 60730-1:2013, including Amendment 1:2015 and Amendment 2:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1530/FDIS	72/1539/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This part 2-5 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the sixth edition of that standard. Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This part 2-5 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: Particular requirements for automatic electrical burner control systems.

Where this part 2-5 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

When a particular clause or subclause of Part 1 is not mentioned in this part 2, that clause or subclause applies.

In the development of a fully international standard, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The reader's attention is drawn to the fact that Annex Q, Annex R, Annex S and Annex T list all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

In this publication, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type;
- defined terms: **bold type**.

Subclauses, notes or items which are additional to those in Part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

1 Scope

This clause of Part 1 is replaced by the following:

This part of IEC 60730 applies to automatic electrical **burner control systems** for the **automatic control** of burners for oil, gas, coal or other combustibles intended to be used

- for household and similar use;
- in shops, offices, hospitals, farms and commercial and industrial applications;

NOTE 1 Throughout this document, where it can be used unambiguously, the word "system" means "**burner control system**" and "systems" means "**burner control systems**".

- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

NOTE 2 Throughout this document, the word "equipment" means "appliance and equipment."

EXAMPLE 1 Controls for commercial catering, heating and air-conditioning equipment.

- that are **smart enabled controls**;

EXAMPLE 2 Remote interfaces/control of burner operations.

- that are AC or DC powered controls with a **rated voltage** not exceeding 690 V AC or 600 V DC;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using **NTC** or **PTC thermistors** and to discrete **thermistors**, requirements for which are contained in Annex J;
- that are mechanically or electrically operated, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof;
- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 3 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document is applicable

- to a complete **burner control system**;
- to a separate **programming unit**;
- to a separate electronic high-voltage **ignition source**;
- to a separate **flame detector**, and
- to a separate **high-temperature operation (HTO) detector**.
- to a **burner control system** intended to be used in warm air heating appliances (furnaces) where the appliance is equipped with an electromechanical differential pressure control to monitor the difference of the combustion air pressure (Type 2.AL). This pressure control provides a switch as an alternative to one of the two switching elements to directly de-energize the safety relevant terminals.

This document does not apply to thermoelectric flame supervision controls; thermoelectric flame supervision controls are covered by ISO 23551-6:2021.

This document also applies to electrical **burner control systems** intended exclusively for industrial process applications e.g. those applications covered by ISO TC 244 (ISO 13577 series).

This document applies to controls powered by primary or secondary batteries, requirements for which are contained within the standard.

This document applies to

- the inherent safety of automatic electrical **burner control systems**, and
- functional safety of automatic electrical **burner control systems**,
- automatic electrical **burner control systems** where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,
- the operating values, operating times, and operating sequences where such are associated with burner safety and to the testing of automatic electrical **burner control systems** used in, on, or in association with, burners.

NOTE 4 Requirements for specific **operating values**, **operating times** and **operating sequences** are given in the standards for appliances and equipment.

This document specifies the requirements for construction, operation and testing of automatic electrical **burner control systems** used in, on, or in association with an equipment.

This document applies also to systems

- incorporating electronic devices,
- using **NTC** or **PTC thermistors**, additional requirements for which are contained in Annex J,
- to the electrical and functional safety of controls capable of receiving and responding to communications signals. The signals can be transmitted to or received from external units, connected wired or wireless, that can or can not be part of the **burner control system**.

This document does not

- take into account the response value of an automatic action of a control, if such a response value is dependent upon the method of mounting the control in the equipment. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply;
- address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

2 Normative references

This clause of Part 1 is applicable except as follows:

Addition:

IEC 60068-2-6, *Environmental testing - Part 2: Tests - Test Fc: Vibration (sinusoidal)*

ISO/IEC 80079-20-1:2017, *Explosive atmospheres - Part 20-1: Material characteristics for gas and vapour classification - Test methods and data*

Bibliography

Bibliography of Part 1 is applicable except as follows:

Addition:

IEC 60127-1:2023, *Miniature fuses - Part 1: Definitions for miniature fuses and general requirements for miniature fuse-links*

IEC 60730-2-6, *Automatic electrical controls - Part 2-6: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements*

IEC 60947-1:2020, *Low-voltage switchgear and controlgear - Part 1: General rules*

IEC 62282-3-100, *Fuel cell technologies - Part 3-100: Stationary fuel cell power systems - Safety*

ISO 13577 (all parts), *Industrial furnaces and associated processing equipment - Safety*

ISO 23551-6:2021, *Safety and control devices for gas burners and gas-burning appliances - Particular requirements - Part 6: Thermoelectric flame supervision controls*

EN 60730-2-5, *Automatic electrical controls - Part 2-5: Particular requirements for automatic electrical burner control systems*

UL 60730-2-5, *Automatic electrical controls - Part 2-5: Particular requirements for automatic electrical burner control systems*

JIS C 9730-2-5, *Automatic electrical controls for household and similar use - Part 2-5: Particular requirements for automatic electrical burner control systems*

CSA E60730-2-5, *Automatic electrical controls - Part 2-5: Particular requirements for automatic electrical burner control systems*