

TECHNICAL SPECIFICATION

**Low-voltage auxiliary power systems -
Part 2-2: Design criteria - Low-voltage DC auxiliary power systems for
substations**

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references.....	5
3 Terms, definitions and abbreviated terms.....	7
3.1 Terms and definitions.....	7
3.2 Abbreviated terms.....	7
4 General requirements.....	8
4.1 General.....	8
4.1.1 System typical configuration.....	8
4.1.2 Design principles.....	8
4.2 Electrical requirements.....	9
4.2.1 Design considerations.....	9
4.2.2 System earthing.....	10
4.2.3 System voltage.....	10
4.2.4 Overvoltage protection and insulation coordination.....	10
4.2.5 Requirements of AC source.....	10
4.3 Safety requirements.....	11
4.4 Environment requirements.....	11
5 Load.....	11
5.1 General requirements.....	11
5.2 Load classification.....	11
5.3 Load calculation.....	12
6 System structure and wiring.....	13
6.1 General requirements.....	13
6.2 Typical structure of the main part.....	13
6.2.1 Basic system.....	13
6.2.2 System with two sets of batteries.....	14
6.3 Distribution network.....	15
6.3.1 General requirements.....	15
6.3.2 Star network.....	15
6.3.3 Meshed network.....	17
7 Protection, monitoring and control.....	18
7.1 General requirements.....	18
7.2 System protection.....	19
7.2.1 Configuration principle.....	19
7.2.2 Selection of protective devices.....	19
7.2.3 Protection selectivity and coordination.....	20
7.3 Monitoring and control.....	20
7.3.1 Configuration principles.....	20
7.3.2 Data collection and alarms.....	21
7.3.3 Main monitor.....	21
7.3.4 Battery monitor.....	21
7.3.5 IMD and IFLS.....	22
8 Equipment selection.....	22
8.1 General requirements.....	22
8.2 Battery.....	22

8.2.1	General requirements	22
8.2.2	Battery size	23
8.3	Charger	24
8.3.1	General requirements	24
8.3.2	Technical characteristics requirement	25
8.4	Cable	26
8.4.1	General requirements	26
8.4.2	Electrical performance requirements	26
8.5	Cabinet and distribution board	27
8.5.1	General requirements	27
8.5.2	Electrical performance requirements	27
8.6	Battery discharge equipment.....	28
8.6.1	General requirements	28
8.6.2	Electrical performance requirements	28
8.7	DC/DC converter	29
8.7.1	General requirements	29
8.7.2	Technical characteristics requirements.....	29
8.8	Complete set of DC power supply.....	29
8.8.1	General requirements	29
8.8.2	Electrical performance requirements	29
9	Equipment layout.....	30
9.1	General requirements.....	30
9.2	Battery layout requirements	30
Annex A (informative)	Demand factor for load statistics	31
Annex B (informative)	Signal information table	32
Bibliography		35
Figure 1	– Schematic diagram of a DC APS	8
Figure 2	– Typical wiring diagram of single battery with single charger scheme.....	13
Figure 3	– Typical wiring diagram of two batteries with two-charger scheme	14
Figure 4	– Typical wiring diagram of two batteries with three chargers-scheme	15
Figure 5	– Typical wiring diagram of star connection	16
Figure 6	– Typical wiring diagram of star connection with sub-distribution boards.....	17
Figure 7	– Typical wiring diagram of loop connection network	18
Table 1	– Main parameters of the charger	25
Table A.1	– Reference values of demand factor for load statistics	31
Table B.1	– Signal information table	32

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Low-voltage auxiliary power systems -
Part 2-2: Design criteria -
Low-voltage DC auxiliary power systems for substations**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 63346-2-2 has been prepared by IEC project committee 127: Low-voltage auxiliary power systems for electric power stations and substations. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
127/86/DTS	127/89/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 63346 series, published under the general title *Low-voltage auxiliary power systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

1 Scope

This part of IEC TS 63346 provides common rules and specific requirements for the design of low voltage DC auxiliary power systems (APs) intended to be installed in substations, mainly covering the configuration of DC power sources, system wiring, electric equipment selection and physical layout.

For the purpose of interpreting this document, a DC APS in this document is considered as follows.

- Its scope covers from the low voltage AC input of the charger to the DC input points of loads. Though DC load is discussed where necessary, the load itself is beyond the scope of this document.
- Unless particularly stated, DC APS refers to the system using lead-acid and nickel-cadmium cells which are connected in series. The system using parallel cells can implement this document by reference.

Substations in this document refer to those which are part of an electrical system and contain equipment that either receives and distributes electrical energy or transforms voltages to the levels required by the loads they supply, or both.

This document does not apply to the design of any of the following:

- traction substation, which have different power supply requirements, such as unbalanced load power supply and harmonic behaviour;
- offshore substations, as factors such as waves, typhoons, salt spray, etc. need to be taken into account, which have different requirements for power supply and equipment selection;
- the substation connecting a nuclear power plant to the grid and its associated LV APS integrated with the nuclear power plant.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60287 (all parts), *Electric cables - Calculation of the current rating*

IEC 60364-1, *Low-voltage electrical installations - Part 1: Fundamental principles, assessment of general characteristics, and definitions*

IEC 60364-4-41, *Low-voltage electrical installations - Part 4-41: Protection for safety - Protection against electric shock*

IEC 60364-4-42, *Low-voltage electrical installations - Part 4-42: Protection for safety - Protection against thermal effects*

IEC 60364-4-43, *Low-voltage electrical installations - Part 4-43: Protection for safety - Protection against overcurrent*

IEC 60364-4-44, *Low-voltage electrical installations - Part 4-44: Protection for safety - Protection against voltage disturbances and electromagnetic disturbances*

IEC 60364-5-51, *Electrical installations of buildings - Part 5-51: Selection and erection of electrical equipment - Common rules*

IEC 60364-5-52, *Low-voltage electrical installations - Part 5-52: Selection and erection of electrical equipment - Wiring systems*

IEC 60623, *Secondary cells and batteries containing alkaline or other non-acid electrolytes - Vented nickel-cadmium prismatic rechargeable single cells*

IEC 60664-1:2020, *Insulation coordination for equipment within low-voltage supply systems - Part 1: Principles, requirements and tests*

IEC 60896-11, *Stationary lead-acid batteries - Part 11: Vented types - General requirements and methods of tests*

IEC 60896-22, *Stationary lead-acid batteries - Part 22: Valve regulated types - Requirements*

IEC 60898-3, *Electrical accessories - Circuit-breakers for overcurrent protection for household and similar installations - Part 3: Circuit-breakers for DC operation*

IEC 60947-2, *Low-voltage switchgear and controlgear - Part 2: Circuit-breakers*

IEC 61056-1, *General purpose lead-acid batteries (valve-regulated types) - Part 1: General requirements, functional characteristics - Methods of test*

IEC 61439-1:2020, *Low-voltage switchgear and controlgear assemblies - Part 1: General rules*

IEC 61439-2, *Low-voltage switchgear and controlgear assemblies - Part 2: Power switchgear and controlgear assemblies*

IEC TR 62060:2001, *Secondary cells and batteries - Monitoring of lead acid stationary batteries - User guide*

IEC 62259, *Secondary cells and batteries containing alkaline or other non-acid electrolytes - Nickel-cadmium prismatic secondary single cells with partial gas recombination*

IEC 62485-2, *Safety requirements for secondary batteries and battery installations - Part 2: Stationary batteries*

IEC TS 63346-1-1, *Low-voltage auxiliary power systems - Part 1-1: Terminology*

IEC 63346-2-1, *Low-voltage auxiliary power systems - Part 2-1: Design criteria - General requirements*¹

¹ Under preparation. Stage at the time of publication: IEC TS/BPUB 63346-2-1:2025.

Bibliography

IEC 60050-195, *International Electrotechnical Vocabulary (IEV) - Part 195: Earthing and protection against electric shock*, available at www.electropedia.org

IEC 60050-482, *International Electrotechnical Vocabulary (IEV) - Part 482: Primary and secondary cells and batteries*, available at www.electropedia.org

IEC 60050-826, *International Electrotechnical Vocabulary (IEV) - Part 826: Electrical installations*, available at www.electropedia.org

IEC 60445, *Basic and safety principles for man-machine interface, marking and identification - Identification of conductors by colours or alphanumerics*

IEC 61557-8, *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. - Equipment for testing, measuring or monitoring of protective measures - Part 8: Insulation monitoring devices for IT systems*

IEC 61557-9, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC - Equipment for testing, measuring or monitoring of protective measures - Part 9: Equipment for insulation fault location in IT systems*

IEC 61660-1, *Short-circuit currents in d.c. auxiliary installations in power plants and substations - Part 1: Calculation of short-circuit currents*

IEEE Std 485, *IEEE recommended practice for sizing lead-acid batteries for stationary applications*

IEEE Std 1115, *IEEE recommended practice for sizing nickel-cadmium batteries for stationary applications*
